



J.P. COLLEGE OF ENGINEERING

College Road, Ayikudy, Tenkasi – 627 852.

Approved by AICTE, New Delhi & Affiliated to Anna University, Chennai

NAAC Accredited with "A" Grade & An ISO 9001: 2015 Certified Institution



TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 19276/RFL/NMSB/2025

Dated: 01/09/2025

District Office,
Fire and Rescue Service,
Tenkasi District.

RENEWAL OF FIRE LICENSE

Ref: (1) Letter no:322714 from the M/S JP COLLEGE OF ENGINEERING, Dated: 26/08/2025

The Fire License is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for In the name of M/S **JP COLLEGE OF ENGINEERING**, AGARAKATTU TO TENKASI ROAD,, AGARAKATTU, AYIKUDI, KADAYANALLUR, Tenkasi, 627852. Consisting of _____G+2_____floors within the jurisdiction of KADAYANALLUR based on the inspection was done by the District Officer Tenkasi on 26.08.2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEARS** from 01.09.2025 to 31.08.2028 and should be renewed on 31.08.2028.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. All Staff should be trained in preliminary firefighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
4. Mock drill should be periodically conducted.
5. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
6. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
7. Emergency fire exit, staircases and doors should not be obstructed.
8. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
9. All the electrical equipment, fitting, accessories and Wiring system should be maintained as per NBC 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

Signature valid
Southern Region District Officer,
Home Department,
Date:01-Sep-2025 17:29:57
District Officer,

Fire and Rescue Services
Tenkasi District

